ಶ್ರೀ ಕೆ. ಪ್ರಭಾಕರ್ .—ಸ್ವಾಮಿ, ಹಿಂದೆ ಈ ಪುಸ್ತಕಗಳನ್ನು ಹಿಂದು ಪವಿತ್ರ ಗ್ರಂಥ ಎಂದು ತಿಳಿದುಕೊಂಡಿದ್ದೆವು. ಒಂದೇ ಸಣ್ಣಪುಟ್ಟ ತಪ್ಪುಗಳೂ ಕೂಡ ಆಗುತ್ತಿರಲಿಲ್ಲ, ಈಗ ಈ ರೀತಿ ಆಗುತ್ತಾ ಇರುವುದಕ್ಕೆ ಕಾರಣ ಏನು ಎನ್ನುವುದನ್ನು ತಿಳಿಸುತ್ತೀರಾ?

ಶ್ರೀ ಎ. ಆರ್. ಬದರಿನಾರಾಯಣ್ .—ಕೆಲವು ಪುಸ್ತಕಗಳನ್ನು ಗೌರ್ನಮೆಂಟ್ ಪ್ರಿಂಟಿಂಗ್ ಪ್ರೆಸ್‌ನಲ್ಲಿ ಮಾಡಿಸುತ್ತೇವೆ, ಕೆಲವು ಪುಸ್ತಕಗಳನ್ನು ಪ್ರೈವೇಟ್ ಪ್ರಿಂಟಿಂಗ್ ಪ್ರೆಸ್‌ನಲ್ಲಿ ಮಾಡಿಸುತ್ತೇವೆ. ಇದು ಬಹುಶಃ ಪ್ರೈವೇಟ್ ಪ್ರಿಂಟಿಂಗ್ ಪ್ರೆಸ್‌ನಲ್ಲಿ ಅವರ ಹಿಂದು ಕಾರ್ಯದ ಒತ್ತಡದಿಂದ ಈ ರೀತಿ ತಪ್ಪು ಬಿದ್ದಿರಬಹುದು. ಆ ರೀತಿ ತಪ್ಪು ಮಾಡಿದ್ದವರಿಗೆ ಏನು ಶಿಕ್ಷೆ ಮಾಡಬೇಕೋ ಅದೆನ್ನು ಮಾಡಿದ್ದೇವೆ.

SRI B. B. SAYANAK .—When is the Government going to take action against the printers and the proof readers?

SRI A. R. BADARINARAYAN .—We have already taken action against the Printers.

SUPPLYING ELECTRICITY TO I. P. SETS OF GOPINATHA AND OTHER VILLAGES OF KOLLEGAL TALUK.

519. SRI R. RACHE GOWDA (Hanur) —

Will the Minister of Pubilc Works and Electricity be pleased to state :—

(*a*) When the estimates for supplying electricity to I. P. sets of Gopinatha and Kurathi-Housr villages of Kollegal taluk were prepared ;

(*b*) the estimated amount in respect of each of them ;

(*c*) the reason for not according sanction ;

SRI H. M. CHANNABASAPPA (Minister for Public Works and Electricity. —

(*a*) and (*b*) Estimate amounting to Rs 5,01,450 for arranging power supply to 57 I. P. sets at Gopinatha village was prepared on 15-4-1971, while that amounting to Rs. 1,94,000 for power supply to 30 I.P. sets at Kurathi-Hosur was perpared on 14-4-1971.

(*c*) The estimates could not be processed by the M. S. E. B. as the Voltage regulation was beyond permissible limits.

ಶ್ರೀ ಆರ್. ರಾಜೇಗೌಡ : ಸ್ಯಾಪು (೧) ಗೆ ಉತ್ತರವಾಗಿ ವಿದ್ಯುದ್ಬಲ (ವೋಲ್ಟೇಜ್)ದ ನಿಯಂತ್ರಣವು ಪರಿಮಿತಿಗೊಳಿಸುವುದುದಕ್ಕಿಂತ ಹೆಚ್ಚಾಗಿದ್ದುದರಿಂದ ಮೈಸೂರು ರಾಜ್ಯದ ವಿದ್ಯುಚ್ಛಕ್ತಿ ಮಂಡಲಿಯವರು ಅಂದಾಜುಗಳನ್ನು ಪರಿಷ್ಕರಿಸಲು ಸಾಧ್ಯವಾಗಿಲ್ಲ ಎಂದು ಹೇಳಿದ್ದೀರಿ. ಆದುದರಿಂದ ವಿದ್ಯುಚ್ಛಕ್ತಿ ಮಂಡಲಿಯವರು ಈ ವಿದ್ಯುದ್ಬಲ (ವೋಲ್ಟೇಜ್) ನಿಯಂತ್ರಣವನ್ನು ಹೆಚ್ಚು ಮಾಡುವುದಕ್ಕೆ ಒಂದು ಸಬ್ ಸ್ಟೇಷನ್‌ನ್ನು ಕೌದಳ್ಳಿಯಲ್ಲಿ ಮಾಡುವುದಕ್ಕೆ ಪ್ರಯತ್ನ ಮಾಡುತ್ತೀರಾ?

ಶ್ರೀ ಎ. ಆರ್. ಬದರಿನಾರಾಯಣ್.—ಅದರ ಬಗ್ಗೆ ಆಗಲೇ ಕ್ರಮ ತೆಗೆದುಕೊಂಡಿದ್ದಾರೆ. ಅದನ್ನು ಸರಿಪಡಿಸುವುದಕ್ಕೆ ಏನು ಕಾರ್ಯಕ್ರಮ ಕೈಗೊಳ್ಳಬೇಕೋ ಅದನ್ನು ಸಹ ಆವಾಗಲೇ ತೆಗೆದುಕೊಂಡಿದ್ದಾರೆ.

† ಶ್ರೀ ಹೆಚ್. ಎಂ. ಚೆನ್ನಬಸಪ್ಪ : ಈಗಾಗಲೇ ಹನೂರಿನಿಂದ ಕೌದಳ್ಳಿಗೆ ೧೧. ಕೆವಿ. ಲೈನ್ ಸರ್ಕ್ಯೂಟ್ ಮಾಡಬೇಕೆಂದು ಒಂದು ಅಂದಾಜು ತಯಾರಾಗಿದೆ, ಅದು ಈಗ ಎಂ. ಎಸ್. ಇ. ಬಿ, ಯವರ ಪರಿಶೀಲನೆಯಲ್ಲಿದೆ.

ಶ್ರೀ ಆರ್. ರಾಚೇಗೌಡ : ಅದನ್ನು ಎಷ್ಟು ವರ್ಷದಲ್ಲಿ ಮಂಗಿಸಲಿಕ್ಕೆ ಪ್ರಯತ್ನ ಮಾಡುತ್ತೀರಿ?

ಶ್ರೀ ಹೆಚ್. ಎಂ. ಚೆನ್ನಬಸಪ್ಪ : ಅದನ್ನು ತೀವ್ರಗತಿಯಲ್ಲಿ ಮಾಡಬೇಕೆಂದು ಪ್ರಯತ್ನ ಮಾಡುತ್ತಿದ್ದೇವೆ ಆದಕ್ಕೆ ಕನಿಷ್ಠ ಪ್ರಮಾಣದ ಕಾಲ ಎಷ್ಟು ಬೇಕೋ ಅಷ್ಟು ಕಾಲ ತೆಗೆದುಕೊಳ್ಳುತ್ತೇವೆ.

ELECTRIFICATON OF VILLAGES IN HOLENARASIPURA TALUK AND DANDIGANAHALLI HOBLI

532. SRI H. D. DEVEGOWDA (Holenarsipura) .—

Will the Minister for Public Works and Electricity be pleased to state :—

(*a*) whether it has come to the notice of the Government that Rural Electrification Programme in Holenarasipur taluk and in Dandiganahalli hobli in Channarayapatna taluk is not satisfactory as comared to other areas in the state ;

(*b*) the number of villages electrified so far in Holenarasipura taluk and in Daudiganahalli hobli in Channarayapatna taluk ;

(*c*) whether any estimate has been prepared for drawing Sub-transmission Lines in Holenarasipur taluk and also in Dandiganahalli hobli in Channarayapatna taluk ;

(*d*) if so. the estimated cost of each sub- Transmission line ;

(*e*) when these works will be completed?

SRI H. M. Channabasappa (Minister for Public Works and Electricity).—

(*a*) No.

(*b*) 64 villages in Holenarasipur taluk and 5 villages in Dandiganahalli hobli in Channarayapatna taluk have been electrified upto the end of June 1972.